

IEA Bioenergy Conference - Berlin, 27th, October 2015

Techno-economic evaluation of selected decentralised CHP applications based on biomass combustion with steam turbine and ORC processes

Dipl.-Ing. Alfred Hammerschmid



BIOS BIOENERGIESYSTEME GmbH

Hedwig-Katschinka-Straße 4, A-8020 Graz, Austria

TEL.: +43 (316) 481300; FAX: +43 (316) 4813004

E-MAIL: office@bios-bioenergy.at

HOME PAGE: <http://www.bios-bioenergy.at>



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Content

- **Introduction and objectives**
- **Case studies: technical description**
- **Case studies: economic assessment**
- **Sensitivity analysis**
- **Summary and conclusions**



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Introduction

- In **2004** the project “Decentralised CHP technologies based on biomass combustion – state of development, demonstration activities, economic performance” had been performed within the IEA Bioenergy Agreement Task 32.
- The main objectives were to gain an overview of **technological and economic developments and demonstration activities**. **4 case studies** with a capacity range of up to 20 MW_{eI} were investigated.
- In the **last 10 years** the technologies available for small scale biomass CHP systems have **developed considerably**.
- For this reason an **update of the assessment** for the most successful CHP technologies has been performed.



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Objectives

- **3 different selected case studies** have been investigated:
 - Biomass-fired steam turbine plant in Austria ($5.7 \text{ MW}_{\text{el,gross}}$)
 - Biomass fired ORC plant in Estonia ($2.4 \text{ MW}_{\text{el,gross}}$)
 - Biomass fired Direct Exchange ORC plant in Slovakia ($130 \text{ kW}_{\text{el,gross}}$)

- Due to very different plant sizes and local side constraints a **direct comparison of the case studies is not meaningful.**



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz


Case Study 1: Steam turbine plant in Austria

- **Start-Up: 2012**
- **CHP technology - Design:**
 - **Backpressure steam turbine**
 - **Steam temperature 525°C**
 - **Steam pressure 90 bar**
 - **Heat consumer: district heating network**
- **Operation mode: Mainly heat controlled**
- **Manufacturer steam boiler: Weiss GmbH**
- **Manufacturer steam turbine: MAN Diesel und Turbo**
- **Technology maturity: commercial**



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Case Study 1: Steam turbine plant in Austria





BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz


Case Study 2: ORC plant in Estonia

- **Start-Up: 2012**
- **CHP technology - Design:**
 - **ORC split process**
 - **Thermal oil boiler with HT+LT thermal oil circuit**
 - **Thermal oil flow temperature 310°C**
 - **Integrated flue gas condensation unit**
 - **Heat consumer: district heating network**
- **Operation mode: Heat controlled**
- **Manufacturer thermal oil boiler: Polytechnik**
- **Manufacturer ORC: Turboden s.r.l**
- **Technology maturity: commercial**



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Case Study 2: ORC plant in Estonia





BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz


Case Study 3: Direct exchange ORC plant in Slovakia

- **Start-Up: 2014**
- **CHP technology - Design:**
 - **Direct exchange ORC process without an intermediate thermal oil cycle**
 - **Flue gas temperature entering ORC system: up to 530°C**
 - **Heat consumer: process heat in saw mill**
- **Operation mode: Heat controlled**
- **Manufacturer biomass burner: Fiedler**
- **Manufacturer ORC: Triogen**
- **Technology maturity: demonstration (1st year of operation)**



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Case Study 3: Direct exchange ORC plant in Slovakia





BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation Methodology

- The **techno-economic assessment** of the different CHP technologies has been performed based on the **VDI 2067** taking capital, consumption, operating and other costs into account.
- For the evaluation of CHP plants the **heat and electricity generation costs** have been **considered independently**. For this reason the overall investment as well as operational costs were split in a heat related part based on a virtual hot water boiler with the same thermal capacity as the CHP plant and in a part for the CHP surplus necessary for electricity production.
- A **sensitivity analysis** has been performed to evaluate the **most important influencing factors**.



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation

Capacity and production

	Unit	DE-ORC	ORC-EST	ST-A
Nominal conditions				
Fuel energy input CHP plant	[kW _{NCV}]	1.110	14.200	27.860
Electric capacity CHP plant gross	[kW _{el}]	130	2.400	5.700
Electric capacity CHP plant net	[kW _{el}]	90	2.050	5.000
Heat capacity CHP module *	[kW _{th}]	660	9.580	17.000
Total efficiency gross	[%]	71,2	84,4	81,5
Annual conditions				
Full load operating hours CHP	[h/a]	7.500	5.140	7.807
Total fuel energy input CHP (100%)	[kWh _{NCV} /a]	9.028.000	74.830.000	200.000.000
Electricity production gross	[kWh _{el} /a]	975.000	12.336.000	44.500.000
Electric efficiency gross	[%]	10,8	16,5	22,3
Heat production	[kWh _{th} /a]	5.265.000	55.943.000	93.000.000
Thermal efficiency	[%]	58,3	74,8	46,5
Total efficiency gross	[%]	69,1	91,2	68,8
Specific electricity consumption CHP plant	[kWh _{el} /MWh _{th}]	48,0	46,1	29,1
Total electricity consumption CHP	[kWh _{el} /a]	299.520	3.145.000	4.000.000
Energy sold				
Electricity sold	[kWh _{el} /a]	780.780	10.361.000	42.174.000
Heat sold	[kWh _{th} /a]	5.212.350	55.383.570	90.000.000

* Thermal capacity of flue gas condensation has not been taken into account



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation

Economic side constraints


Parameter	Unit	DE-ORC	ORC-EST	ST-A
Feed-in tariff	[€/MWh _{el}]	110,0	89,9	122,0
Period of feed-in tariff granted	[Years]	15,0	12,0	15,0
Heat price	[€/MWh _{th}]	32,0	45,0	55,0
Interest rate	[%/a]	3,0	3,0	4,0
Fuel price	[€/kWh _{NCV}]	10,0	12,3	21,5
Hourly rate - personnel costs (CHP related)	[€/h]	10	10	55
Annual working hours (CHP related)	[h/a]	53	1.700	1.700
Hourly rate - personnel costs	[€/h]	10	10	45
Annual working hours	[h/a]	130	4.900	5.100
Electricity price (own needs)	[€/kWh _{el}]	70	125	120
Investment costs total	[€]	860.000	12.830.000	24.770.000
Investment subsidy	[€]	-	2.720.000,0	2.317.500



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation

Total investment costs




- Investment costs (heat related)
- Investment costs (CHP related)
- Investment costs (heat related, funding subtracted)
- Investment costs (CHP related, funding subtracted)



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation

Specific investment costs CHP related






BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation

Specific investment costs heat related







BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation

Specific heat generation costs






BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation

Specific electricity generation costs






BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Techno-economic evaluation


Specific total energy generation costs





BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Sensitivity analysis Fuel price






BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Sensitivity analysis

Full load operating hours





BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Conclusion and recommendation (I)

- **All three CHP plant investigated can be operated economically** The results, however, should not be directly compared due to different local economic framework conditions.
- **Overall annual efficiencies achieved are between 69 and 91%,** whereas **gross electric efficiencies vary between 11 and 22%.**
- **For steam turbine and conventional ORC plants the potential for further increase of nominal efficiencies is limited** but a proper design and system integration is essential. For the **direct exchange ORC a potential for further technological improvement exists** and should be used with increased operational experiences.
- **The specific CHP related investment costs vary between 6,500 €/kW_{el} (direct exchange ORC; 130 kW_{el,gross}) and 3,100 €/kW_{el} (steam turbine; 5,700 kW_{el,gross})** outlining the **economy-of-scale-effect.**



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Conclusion and recommendation (II)

- The specific electricity generation costs vary between **99 €/MWh_{el}** (steam turbine) and **109 €/MWh_{el}** (direct exchange ORC).
- The specific energy generation costs are in a range of **33 €/MWh** (direct exchange ORC) and **61 €/MWh** (steam turbine)
- The most important influencing variables for the energy generation costs are the **full load operating hours** and the **fuel price**.
- **> 5,000 – 6,000 full load operating hours** are recommended for the investigated decentralised CHP plants in heat controlled operation.
- **Feed-in tariffs** and **investment subsidies** suited for the plant size and application are, however, **necessary** to enable an economic operation of decentralised CHP plants.



BIOENERGIESYSTEME GmbH
Hedwig-Katschinka-Straße 4, A-8020 Graz

Thank you for your attention

Dipl.-Ing. Alfred Hammerschmid
Hedwig-Katschinka-Straße 4, A-8020 Graz, Austria
TEL.: +43 (316) 481300-72; FAX: +43 (316) 481300-4
E-MAIL: hammerschmid@bios-bioenergy.at
HOME PAGE: <http://www.bios-bioenergy.at>